



Date Submitted: 6/8/2020

Water Use Efficiency Annual Performance Report - 2019

WS Name: TWISP TOWN OF

Water System ID# : 90050

WS County: OKANOGAN

Report submitted by: *Andrew Denham*

Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *01/01/2019* To *12/31/2019*

Incomplete or missing data for the year? *No*

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	<i>83,109,646</i> gallons
Authorized Consumption (AC) – Annual Volume	<i>54,102,676</i> gallons
Distribution System Leakage – Annual Volume TP – AC	<i>29,006,970</i> gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	<i>34.9 %</i>
3-year annual average	<i>30.8 %</i>

Goal-Setting Information:

Date of Most Recent Public Forum: *03/10/2015* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Reduce customer summer water use by 3% in 5 years. Reduce Town Park water use by 10% in 3 years. Maintain tiered rate system incentive to conserve water.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

The Town has initiated leak detection with Evergreen Rural Water and will continue to do so until detectable leaks have been located and rectified.

The Town continues to replace about 35 old meters with a new AMR system each year.

Do not mail, fax, or email this report to DOH